



® TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznámený subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body. Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Notified Body 1020
Branch 0100 – Praha

REPORT

on the assessment of performance

according to the Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011
(the Construction Products Regulation or CPR), Art. 1.4 of the Annex V (system 3)

No. 1020-CPR-010-038558

Trade name:

LG Hausys decorative wallcovering according to EN 15102:2007+A1:2011

type/ variation: **Piya Kids Duvar Kağıtları**

Manufacturer:

SÜS DUVAR KAĞITÇILIK SAN. Ve TİC.A.Ş.

INo:

Address: **Mevlanakapi Merkezefendi Mah. Tekke Sok. No: 6, 34780
Zeytinburnu/Istanbul, Turkey**

Plant:

**SÜS DUVAR KAĞITÇILIK SAN. Ve TİC.A.Ş.
HARAÇÇI MAH. HADIMKÖY YOLU CAD. NO:129,
ARNAVUTKÖY/ ISTANBUL, TURKEY**

Order: **Z010170150**

Number of report pages including title-page: 3

Number of annexes: 1

The person taking responsibility for the content of this report:


Ing. Klára Bednářová
Head Assessor

The person taking responsibility for the correctness of this report:

Stamp of the Notified Body 1020

Praha, August 11, 2017




Ing. Iveta Jiroutová
Deputy Manager of the Notified Body 1020

Note: This Report may not be reproduced otherwise but complete without a written consent of the notified body deputy manager.

Technical and Test Institute for Construction Prague, branch 0100 - Praha, Prosecká 811/76a, 190 00 Praha 9, Czech Republic
Phone: +420 2 86 019 400, +286 885 548, fax: +420 286 891 393, e-mail: info@tzus.cz, <http://www.tzus.cz>
Bank connection: KB Praha 1 Czech Republic, account No.: 1501-931/0100, ID: 000 15679, VAT: CZ00015679

1. Specification of tested subject

1.1. Description and intended use of the product

LG Hausys decorative wallcovering according to EN 15102:2007+A1:2011

type / variation: Piya Kids Duvar Kağıtları

Intended use: decorative wall covering for hanging to internal walls, partitions and ceilings

Composition: non-woven wallpaper made of waterbased ink

Thickness: (185-195) µm

Mass per unit area: 150 g/m²

Product shall be applied to the substrate according to the hanging instructions of the manufacturer.

1.2. Technical specification:

EN 15102+A1 Decorative wall coverings - Roll and panel form

EN 13501-1+A1 Fire classification of construction products and building elements - Part 1: Classification using test data from reaction to fire tests

1.3. Manufacturer and plant:

Manufacturer: SÜS DUVAR KAĞITÇILIK SAN. Ve TİC.A.Ş.

Address: Mevlanakapi Merkezefendi Mah. Tekke Sok. No: 6, 34780 Zeytinburnu/Istanbul, Turkey

Plant address: HARAÇÇI MAH. HADIMKÖY YOLU CAD. NO:129, ARNAVUTKÖY/ISTANBUL, TURKEY

2. Sampling

Place of sampling: warehouse of the manufacturer

Sampler: representative of the manufacturer

Date of the taking over in EFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.: 25.01.2017

3. The assessment of performance on basis of testing, calculation, tabuled values, descriptive documentation

The assessment was carried out on basis of testing.

3.1 The assessment on the basis of the testing and calculation

3.1.1. An inventory of tests reports/classification reports/written declarations

Reaction to fire classification report No. ERA-17-086 of 03.07.2017, issued by EFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş., a.s., Notified Body 2184.

Test results:

Table No. 1:

Characteristic	Obtained data value	Test report/Classification report No.
Reaction to fire (EN 13501-1+A1)	Reaction to fire class: E	ERA-17-086

4. Annexes

Reaction to fire classification report No. ERA-17-086 of 03.07.2017, issued by EFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş., a.s., Notified Body 2184.